

**Nam Ho**  
Fwd: Bonita Creek Water Company Infrastructure  
To: Bryan Staley

4:48 PM

**Siri Found a Contact**  
Nam Ho  
ho.nam@azdeq.gov

Add X

----- Forwarded message -----  
From: **Nam Ho** <ho.nam@azdeq.gov>  
Date: Wed, Oct 12, 2022 at 4:46 PM  
Subject: Re: Bonita Creek Water Company Infrastructure  
To: Linda Taunt <launt.linda@azdeq.gov>  
Cc: Reshet Gebremariam <gebremariam.reshet@azdeq.gov>

Hello Bryan,

In our phone conversation today with Ken, you mention that Bonita Creek Water Company would like to replace your current steel filter vessel with a new filter vessel. The new filter vessel is made of a similar material (steel) and is the same in size. No permitting is required for a like for like replacement. Please proceed with the operation and maintenance of the water system and follow proper disinfection procedures for installation of the filter vessel replacement.

----- Forwarded message -----  
[See More from BCWC](#)

**Nam Ho, P.E.**  
Drinking Water Environmental Engineering Specialist  
Ph: 602-771-4664



Your feedback matters to ADEQ. Visit [azdeq.gov/feedback](https://www.azdeq.gov/feedback)