

COMMISSIONERS
Jim O'Connor - Chairman
Lea Márquez Peterson
Anna Tovar
Kevin Thompson
Nick Myers



Douglas R. Clark
Executive Director

Douglas R. Clark
Interim Utilities Division Director

ARIZONA CORPORATION COMMISSION

August 21, 2023

Ms. Lorna Glaunsinger
Bonita Creek Water Company
251 North Big Al's Run
Payson, Arizona 85541

RE: BONITA CREEK WATER COMPANY
DOCKET NO. W-02195B-21-0029

Notice of Administrative Approval/ Closure

Dear Ms. Glaunsinger,

The above referenced Cross-Connection Tariff became effective by operation of law on March 24, 2021.

By copy of this letter, the Docket Control Center is requested to administratively close Docket No. W-02195B-21-0029. Should you have any questions concerning the above, please contact me at your earliest convenience at (602) 542-0755.

Sincerely,

A handwritten signature in blue ink, appearing to read "Ryan A. Witt", with a long horizontal flourish extending to the right.

Ryan Witt
Chief Engineer
Utilities Division


RAW:eg

Called and spoke with Mr. Witt on 8/28/23. He confirmed that the above Bonita Creek Water Company Docket is no longer active.

On this 21st day of August, 2023, the foregoing document was filed with Docket Control as a Letter Directing Administrative Closure – Tariff, and copies of the foregoing were mailed on behalf of the Utilities Division to the following who have not consented to email service. On this date or as soon as possible thereafter, the Commission's eDocket program will automatically email a link to the foregoing to the following who have consented to email service.

Lorna Glaunsinger
Bonita Creek Water Company
251 N. Big Al's Run
Payson, AZ 85541
lglaunsinger@yahoo.com
Consented to Service by Email

Robin Mitchell
Director/Chief Counsel, Legal Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, Arizona 85007
legaldiv@azcc.gov
utildiverservicebyemail@azcc.gov
Consented to Service by Email

By: 
Elizabeth Griffin
Administrative Support Specialist

CROSS-CONNECTION OR BACKFLOW TARIFF**PURPOSE:**

The purpose of this tariff is to protect Bonita Creek Land & Homeowner's Association ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

****FOR OFFICIAL USE ONLY****

Effective Date: _____

**ADMINISTRATIVELY
APPROVED FOR FILING**

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location
 - c. date(s) of test(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

****FOR OFFICIAL USE ONLY****

Effective Date: _____

**ADMINISTRATIVELY
APPROVED FOR FILING**